

**NOTES**

The final location of the potential transmission line connection into Whitlea substation will be determined after further detailed siting and consultation on this project and the RES Forty Mile Interconnection project.

The Maleb 530S substation will be located within the Customer substation target area.

Temporary workspace will be required 10m north of the right-of-way between the Maleb 530S substation target area and B10, or 10m south of the right-of-way from the Maleb 530S substation target area to A10 and A20.

20m x 20m permanent guy wire easements will be required where ninety degree turns occur on the potential routes. 80m x 30m temporary construction workspace will also be required in these areas as shown.

If the route goes from the Maleb 530S substation target area to B10 to A20 to A30, 20m x 20m permanent easement and 80m x 30m temporary construction workspace will be required at A20.

The setback distance from Township Road 80 to the potential transmission line from the Maleb 530S substation target area to B10 is 30m from the edge of the road allowance.


The setback distance from Township Road 80 to the potential transmission line from A10 to A20 is 45m from the edge of the road allowance to provide an optimal location for the 964L/983L transmission line crossing.



**LEGEND**

- Point Designation
- Potential Upgrade to Existing Substation
- Potential Transmission Line
- - - Existing Transmission Line
- 30m Right of Way Boundary
- ▭ Customer Substation Target Area
- Potential Guy Anchor Easement
- ▭ Potential Temporary Construction Workspace
- Residence
- Wellsite
- Pipeline
- Road
- Other Altalink Project
- Potential RES Forty Mile Transmission Line

NO: 35023055 - 6201  
 DRAWN: SG - AL  
 FILE NO.: XXXXXXX  
 REVISION: 0.03.03  
 AL FOLDER: Suncor Forty Mile WAGF Transmission Line Interconnection  
**DATE: 2017-03-27**



Service Layer Credits: © 2017 DigitalGlobe Image courtesy of USGS © 2017 GeoEye Earthstar Geographics SIO © 2017 Microsoft Corporation  
 Although there is no reason to believe that there are any errors associated with the data used to generate this product or in the product itself, users of these data are advised that errors in the data may be present.

**DETAIL PHOTO DP1**



**POTENTIAL**  
 Suncor Forty Mile  
 Wind Power Connection Project