



NOTES

The right-of-way boundary for the proposed transmission line is approximately 20 metres wide.

The vegetation control easement (VCE) is approximately 20 metres wide on both sides of the proposed right-of-way.


Additional right-of-way of approximately 8 metres will be required between A30 and B10 for the proposed modifications to the 745AL transmission line.

Guy anchor easements of approximately 10 m x 82 m and 10 m x 80 m will be required west of A5 and east of A30.

The proposed optical ground wire (OPGW) will be installed on the existing 745AL transmission line. The proposed underground fibre optic cable will be installed within the existing 745AL transmission line right-of-way.

| LEGEND | | |
|---|--|---------------------|
| ● Point Designation | — Proposed 20m Right of Way Boundary | — Road |
| ■ Existing Substation | ▭ Proposed Customer Substation Target Area | ▨ Oil and Gas Plant |
| — Proposed Transmission Line | ▭ Proposed Guy Anchor | ■ Water Body |
| — Proposed Transmission Line Modification | ● Proposed Vegetation Control Easement | |
| — Previously Considered Transmission Line | ● Wellsite | |
| — Proposed Optical Ground Wire | — Pipeline | |
| — Proposed Underground Fibre Optic Cable | — Railway | |
| — Existing Transmission Line | — River or Stream | |

NO: 35023595 - 6201
 DRAWN: SG - AL
 FILE NO.: XXXXXXX
 REVISION: 1.05.14
 AL FOLDER: TPG Canyon Creek
DATE: 2021-01-04



DETAIL PHOTO **DP1**



PROPOSED
 Turning Point Generation
 Canyon Creek Connection

Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community
 Although there is no reason to believe that there are any errors associated with the data used to generate this product or in the product itself, users of these data are advised that errors in the data may be present.